

GOVERNMENT OF ANDHRAPRADESH
DIRECTORATE OF I.P.M.PH.LABS, FOOD (H) ADMN, Mangalagiri, Guntur.
REGIONAL PUBLIC HEALTH LABORATORY, GUNTUR

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample from	Dr.Kondabolu Lakshmi Prasad Public School, JKC College Road, Guntur, Guntur Dt.	Lab. Ref. No:	1925
		Collected on	13-03-2026
		Received on	13-03-2026
Collected by	Self.	Source Profile	Ro water

		Source / Sample	Limits as per IS 10500:2012	
		Drinking water tap (R0) at above address.		
S. No	Parameter		Desirable (Acceptable limit)	Permissible limit in the absence of alternative source
Physical Parameters				
1	Colour (Hazen units)	<5.0	5	15
2	Turbidity in NTUS''	0.1	1	5
3	Odour	Unobjectionable	Unobjectionable	Agreeable
4	pH	6.9	6.5 – 8.5	No relaxation
5	Conductivity at 25 °C (Micro Mhos/ Cm)	100	...	
6	TDS (mg/L)	66	500	2,000
Chemical parameters (mg/L)				
1	Alkalinity (as CaCO ₃)	Nil	...	
2	Total Alkalinity. Max	16	200	600
3	Total hardness max	28	300	600
4	Calcium hardness (as CaCO ₃)	16	..	
5	Magnesium hardness (as CaCO ₃)	12	..	
6	Calcium (as Ca)	6.0	75	200
7	Magnesium (as Mg)	3.0	30	100
8	Ammonical Nitrogen	Nil	...	
9	Nitrite (as N)	Nil	...	
10	Chloride (as Cl)	20	250	1,000
11	Fluoride (as F)	0.1	1	1.5
12	Iron (as Fe)	Nil	0.3	No relaxation

Remarks: The given sample physico chemically all the analysed parameters are with in the desirable limits and satisfactory for drinking purpose.



R. P. N. Reddy
16/3
Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur - 4.

GOVERNMENT OF ANDHRA PRADESH
DIRECTORATE OF I.P.M., P.H.LABS, FOOD (H), ADMINISTRATION, Mangalagiri, Guntur
REGIONAL P.H.LABORATORY, MEDICAL COLLEGE CAMPUS, GUNTUR -4
REPORT OF MICROBIOLOGICAL ANALYSIS OF WATER

Sample(s) from: Dr.Kondabolu Lakshmi Prasad Public School,JKC College Road,Guntur,Guntur Dt.

Collected on: 13.03.2026

Received on : 13.03.2026

Paid / Free : Paid

Collected by : Self

S.No	Lab Ref. No	SOURCE	Residual Chlorine mg.per litre	MPN of Coliform Bacteria Per 100 ml.	Nature of Coliform Bacteria Isolated	MP N of Esch coli.
1	1926	Drinking water tap (Ro) at above address.	Nil	Nil	-	-

Remarks:- The given sample is bacteriologically Satisfactory for drinking purpose as evidenced by the Nil MPN count of coliform bacteria.



R. P. N. S.
16/3
Senior Analyst (Water),
Regional Laboratory
Medical College Campus
Guntur-4.